



April 18, 2017

Doug Van Essen, Esq.
 Silver & Van Essen
dww@silvervanessen.com

RE: Cascade Township Park Water Sampling Results

Dear Doug:

Attached is the laboratory report from samples we recently collected from potable wells at Cascade Township Park. The samples were analyzed by Pace in Minneapolis, Minnesota for a limited number of perfluoroalkyl and polyfluoroalkyl substances (PFAS) including perfluorooctane sulfonate (PFOS) and perfluorooctanoic acid (PFOA).

The samples were un-treated groundwater collected from aerator-free outside hose bibs. The laboratory report is summarized below. For reference, the table includes the MDEQ PFOS/PFOA Part 201 Generic Residential and Non-Residential Cleanup Criteria for drinking water of 70 parts per trillion (ppt). Other PFAS substances do not currently have MDEQ Criteria.

Summary of Laboratory Results				Non-PFOS/PFOA detected
Sample	PFOS/PFOA Detected	Total PFOS/PFOA Detected (ppt)	Total PFOS/PFOA Detected Above or Below MDEQ Criteria (70 ppt, or ng/l)	
Potable Well – Maintenance Garage	No	None	Below	None
Potable Well - Bathroom	No	None	Below	None
Field Blank	No	None	Below	None

Thank you for using the services of F&V. If you need additional information, please contact me.

Sincerely,
 FLEIS & VANDENBRINK

Brian L. Rice, P.E.
 Manager, Environmental Services Group

att: Laboratory Report and Chain of Custody

2960 Lucerne Drive SE, Suite 100
Grand Rapids, MI 49546
 P: 616.977.1000
 F: 616.977.1005
www.fveng.com